

FINAL – Coos Bay Wastewater Treatment Plant No.2 Upgrade Cost Estimate

PREPARED FOR: City of Coos Bay

PREPARED BY: Alan Chang/CH2M HILL
William Leaf /CH2M HILL
Miaomiao Zhang/CH2M HILL

REVIEWED BY: Doug Berschauer/CH2M HILL
Bob Lawson/CH2M HILL

DATE: May 15, 2012

Introduction

This memorandum presents the cost estimate for two top alternatives selected in the Coos Bay Wastewater Treatment Plant (WWTP) No.2 Facility Plan Amendment (FPA) (Civil West, draft, September 2011), as well as two top alternatives proposed in the Value Assessment (VA) report (CH2M HILL, November 2011). These alternatives are:

- FPA alternative 1 – New plant with Sequencing Batch Reactor (SBR)
- FPA Alternative 2 – New plant with Conventional Modified Ludzack-Ettinger (MLE)
- VA Alternative 1 – Membrane Bioreactor (MBR), utilizing existing aeration basins and clarifiers
- VA Alternative 2 – Integrated Fixed Film Activated Sludge (IFAS), utilizing existing aeration basins and clarifiers

Although preliminary capital costs have been estimated for those two FPA alternatives during alternative pre-screening, the purpose of this cost estimating is to provide a fair comparison for all four alternatives at the same costing platform. CH2M HILL's cost estimating tool CPES™ (CH2M HILL Parametric Cost Estimating System) will be used to determine the project cost, annual O&M costs and life cycle cost of each alternative. Summary of CPES™ cost estimate of each alternative is included in attachment to this memorandum.

The memorandum summarizes all the assumptions and basis used for the cost estimating and presents the comparison. The cost estimate was based on the proposing vendors' quote as well as engineers' experience at other construction projects. The 2035 design criteria listed within the Facility Plan Amendment are used within this evaluation. One exception is that the design wastewater temperature is proposed to be 15°C, which appears to be the low temperature for the Coos Bay WWTP No. 2 during the compliance period for Ammonia-N. The assumed design temperature used within the equipment quotes included as part of the FPA varied from 10°C to 13°C. It has been noted that the plant discharge monitoring reports (DMR) show that the minimum wastewater temperature from Coos Bay WWTP No. 2 is approximately 13°C.

Treatment Alternatives

This section presents a description of the alternatives under consideration and the basis of design for each used to develop the cost estimate.

FPA Alternative 1 – SBR

This alternative assumes the existing treatment plant No. 2 will be abandoned, with the exception of piping connections to the existing outfall. The new plant will be constructed on a new parcel, across from the existing WWTP. The new site is undeveloped, but free from any existing structures.

Assumptions have been made during cost estimating based on the understanding of the FPA and CH2M HILL's experience on the similar projects. The common assumptions for both FPA alternatives include:

- The process and equipment have been sized to meet the Class I reliability requirements by Environmental Protection Agency (EPA).
- A new headworks building containing screens and grit removal systems is provided. The screening and grit disposal dumpsters are outdoor.
- No primary clarifiers are provided at the new plant.
- A Waste Activated Sludge (WAS) storage tank with over 6 day storage capacity at maximum month condition is provided. WAS is stored and then trucked offsite for treatment.
- Ultraviolet (UV) disinfection is employed to replace existing chlorine system. A high UV dose may be required due to strict discharge coliform requirement in the National Pollutant Discharge Elimination System (NPDES) permit.
- A 3,000-sqft new Administration/Operation & Maintenance (O&M) building is constructed.
- A new 200-kW emergency generator is installed onsite.
- No odor control is included as per the FPA, but this should be evaluated in detail as the project progresses. It may be warranted to have odor control on the new parcel for the headworks facility.

The assumptions specific to SBR alternative include:

- SBR sizing and cost are based on Intermittent Cycle Extended Aeration System (ICEAS) from ITT's proposal. Although the wastewater temperature and the peak flows used in ITT's calculation do not exactly align with the design criteria discussed in the technical memorandum "Preliminary Biological Treatment System Alternative Proposals Review" (Esvelt Environmental Engineering, August 2011), the temperature of 13°C (based on DMRs) used by ITT is conservative for the dry weather condition because the seasonal low temperature during the ammonia compliance period appears to be approximately 15°C. Therefore, the process system sizes proposed have sufficient hydraulic capacity to handle the peak hour flow.
- The scope of supply includes:
 - (2) 40' Decaners with Drive Units (1 decaners per basin)
 - (2) 125-HP Aeration PD Blowers (1 duty & 1 standby)
 - (2) Fine Bubble Aeration Systems (1 system per tank)
 - (2) Automated Air Control Valves
 - (2) DO Control with Probes and Logic (one probe per tank)
 - (2) Waste Activated Sludge (WAS) Pumps
 - (1) ABJ Control Package (including PLC, HMI, Motor Starters/VFD's for above listed equipment, Modem, Level Transmitters and Float Switches, and Local Decanter Control Stations)
 - (10) Service Days
 - (1) Freight

Figure 1 below illustrates the process flow diagram of SBR alternative.

FIGURE 1
FPA Alternative 1 – SBR Process Flow Diagram




Table 1 below lists preliminary process and major equipment determined for this alternative.

TABLE 1

Process and Major Equipment Design Data Sheet, FPA Alternative 1- SBR

Unit Process	Parameter	Note
Influent Pump Station W/ Magmeter		
Pumps		
Type	Submersible	
Peak flow, mgd	8.11	
No. of Pumps	3 + 1	
Capacity of Pump, gpm, ea	2,000	
TDH, ft	20	Assumed
Motor, hp, ea	30/ with VFD	
Wetwell		
Retention Time, min	20	
Depth, ft	10	assumed
Headworks and Grit Removal		
Screens		

TABLE 1

Process and Major Equipment Design Data Sheet, FPA Alternative 1- SBR

Unit Process	Parameter	Note
Mechanical Bar Screen		
Type	Mechanical Bar Screen	
No. of Screens	2 mechanical + 1 manual	
No. of Channels	2 + 1 bypass	
Screen Openings, inch	1/4	
Screen hp, ea	2	
Channel Width, ft	2.2	
Bypass Channel Width, ft	3	
Channel length, ft	9	
Screen Compactor and Washer		
No. of Screen Compactor Washers	2	
Screen Compactor and Washer hp, ea	2	
Grit Removal		
Type	Vortex	
No. of Units	1	
Capacity, mgd, ea	8.1	
Grit Removal Drive hp, ea	1	
Grit Classifier		
No.	1	
hp, ea	1	
Grit Pumps		
No.	1 + 1	
hp, ea	5	
SBR (Per ITT ICEAS)		
No. of Basins	2	
Dimensions of each Basin, ft	123 x 50 x 18 SWD	
Blowers		
No. of Blowers	1 + 1	
Capacity of Blowers, scfm, ea	1170	
Discharge Pressure, psig, ea	8.2	
Horsepower, ea	125	
WAS Pumps		
No. of pumps	1 + 1	
Capacity of Pumps, gpm, ea	131	

TABLE 1

Process and Major Equipment Design Data Sheet, FPA Alternative 1- SBR

Unit Process	Parameter	Note
Horsepower, ea	2.4	
Blower Room (for SBR blowers and WAS Tank Blowers)		
Blower Room Dimensions, ft	38 x 20	
Electrical Room Dimensions, ft	24 x 7	
Overall Dimensions, ft	44 x 24	
WAS Storage Tank		
Volume, MG	0.3	
WAS Production, gpd	46814	Per ITT Calculations
Storage Duration, day	6.4	
Mixing Air required, scfm	802	based on 20 scfm/1000 cf tank
Blowers		
No.	1 + 1	
Capacity, scfm, ea	800	
hp, ea	40	
Coarse Bubble Diffuser (Sanitaire D-24)		
No.	27	
Air flow per Diffuser	30	
UV Disinfection		
System Capacity, mgd	8.11	
UV Dose, mJ/cm ²	45	
No. of Channels	2	
No. of Banks/Channel	1	
No. of Modules/Bank	15	
No. of Lamps/Module	8	
Total No. of Lamps	240	
O&M Building		
Footprint, sf	3000	
Unit Cost, \$/sf	251.5	
Emergency Generator		
Capacity, kw	200	
Enclosure	Sound Attenuation, Weather Proof	
Operation Time, per year	24	
Other Components Included in CPES™		

TABLE 1

Process and Major Equipment Design Data Sheet, FPA Alternative 1- SBR

Unit Process	Parameter	Note
Gravity System Upgrades		
Estuary Outfall Piping and Connection		

Facility Plan Amendment Alternative 2 – Extended Aeration MLE

Same as the SBR alternative, the extended aeration MLE alternative assumes the existing treatment plant No. 2 will be abandoned, with the exception of connections to the existing outfall. The new plant will be constructed on a new parcel, across from the existing WWTP.

The secondary treatment processes are different between two FPA alternatives. The following assumptions/approaches are specific to MLE alternative:

- Aeration basins are sized based on the dry weather maximum month flow and loads, using CH2M HILL's process simulator Pro2D™. The cost of the aeration basins is determined using CPES™. Although Siemens provided proposal of treatment using MLE with clarifier as responses to Civil West's request for proposal in June 2011, the proposal did not contain sufficient details for the engineers to determine if the system is sized adequately or the clear scope of supply corresponding to the quote submitted. No additional information or clarification was obtained from Siemens during this analysis.
- Secondary clarifiers are sized using CH2M HILL's process simulator Pro2D™. The equipment cost is based on Siemens' quote for two Tow-Bro clarifier mechanisms with the standard coated steel construction (\$220,000).

Figure 2 below illustrates the process flow diagram of Extended Aeration MLE alternative.

FIGURE 2
FPA Alternative 2 – Extended Aeration MLE Process Flow Diagram




Table 2 below lists preliminary process and major equipment determined for MLE alternative.

TABLE 2

Process and Major Equipment Design Data Sheet, FPA Alternative 2 - MLE

Unit Process	Parameter	Note
Influent Pump Station W/ Magmeter		
Pumps		
Type	Submersible	
Peak flow, mgd	8.11	
No. of Pumps	3 + 1	
Capacity of Pump, gpm, ea	2,000	
TDH, ft	20	Assumed
Motor, hp, ea	30/ with VFD	
Wetwell		
Retention Time, min	20	
Depth, ft	10	assumed
Headworks and Grit Removal		
Screens		

TABLE 2

Process and Major Equipment Design Data Sheet, FPA Alternative 2 - MLE

Unit Process	Parameter	Note
Mechanical Bar Screen		
Type	Mechanical Bar Screen	
No. of Screens	2 mechanical + 1 manual	
No. of Channels	2 + 1 bypass	
Screen Openings, inch	1/4	
Screen hp, ea	2	
Channel Width, ft	2.2	
Bypass Channel Width, ft	3	
Channel length, ft	9	
Screen Compactor and Washer		
No. of Screen Compactor and Washers	2	
Screen Compactor and Washer hp, ea	2	
Grit Removal		
Type	Vortex	
No. of Units	1	
Capacity, mgd, ea	8.1	
Grit Removal Drive hp, ea	1	
Grit Classifier		
No.	2	
hp, ea	1	
Grit Pumps		
No.	1 + 1	
hp, ea	5	
Aeration Basins (Per Pro2D)		
No. of Basins	2	
Volume of each Basin, MG	1.05	
Aerobic SRT, day	12.5	
Design MLSS, mg/L	2,800	
Design MLVSS, mg/L	1,800	
MLR Pumps		
No. of Pumps	2	
Capacity, gpm, ea	2,000	
Horsepower, ea	10 hp	
Blowers		

TABLE 2

Process and Major Equipment Design Data Sheet, FPA Alternative 2 - MLE

Unit Process	Parameter	Note
No. of Blowers	1 + 1	
Capacity of Blowers, scfm, ea	3,065	
Discharge Pressure, psig, ea	8.1	
Horsepower, ea	150	
Secondary Clarifiers		
No. of Clarifiers	2	
Diameter, ft, ea	70	
WAS/RAS Pump Station		
WAS Pumps		
No. of pumps	1 + 1	
Capacity of Pumps, gpm, ea	100	
Horsepower, ea	1.5	
RAS Pumps		
No. of pumps	1 + 1	
Capacity of Pumps, gpm, ea	700	
Horsepower, ea	10	
Blower Room (for Aeration Basin Blowers and WAS Tank Blowers)		
Blower Room Dimension, ft	46 x 30	
Electrical Room Dimension, ft	26 x 7	
WAS Storage Tank		
Volume, MG	0.3	
WAS Production, gpd	46,400	Per Pro2D Calculations
Storage Duration, day	6.5	
Mixing Air required, scfm	802	based on 20 scfm/1000 cf tank
Blowers		
No.	1 + 1	
Capacity, scfm, ea	800	
hp, ea	40	
Coarse Bubble Diffuser (Sanitaire D-24)		
No.	27	
Air flow per Diffuser	30	
UV Disinfection		
System Capacity, mgd	8.11	

TABLE 2

Process and Major Equipment Design Data Sheet, FPA Alternative 2 - MLE

Unit Process	Parameter	Note
UV Dose, mJ/cm2	45	
No. of Channels	2	
No. of Banks/Channel	1	
No. of Modules/Bank	15	
No. of Lamps/Module	8	
Total No. of Lamps	240	
O&M Building		
Footprint, sf	3000	
Unit Cost, \$/sf	251.5	
Emergency Generator		
Capacity, kw	200	
Enclosure	Sound Attenuation, Weather Proof	
Operation Time, per year	24	
Other Components Included in CPES™		
Gravity System Upgrades		
Estuary Outfall Piping and Connection		

Value Assessment Alternative 1 – MBR

This VA alternative includes converting the existing conventional activated sludge WWTP to a membrane bioreactor plant. Most of the existing structures will remain, but be modified. Some structures will be constructed on the new site across the street. A membrane system quote by GE/Zenon is used as the costing basis.

The following assumptions are made regarding the major processes and equipment in this alternative:

- New influent pump station with four submersible pumps (3 duty and 1 standby) – located on parcel across the street
- New headworks/screening facility on parcel across the street (greenfield site). The facility consists of two mechanical bar screens and one bypass channel with manual clean bar screen, one vortex grit removal, two fine screens required for MBR process and all the ancillary equipment.
- Two existing secondary clarifiers are converted to the primary clarifiers. During peak flows, a coagulant will be added to the primary clarifiers to accomplish chemically enhance primary treatment (CEPT) for higher removal. Partial primary effluent will bypass the biological treatment process and blend with the MBR permeate before discharge.
- New ferric chloride storage and metering system for CEPT during peak wet weather flows. The storage system is sized based on 20 mg/L at 6.24 mgd (peak day flow) for 7-day storage. Multiple totes are required.
- New Flow Splitting structure downstream of CEPT during peak flow.
- New primary sludge pump station.
- Existing aeration basins and electrical room structure, with new diffusers, mixers, and mixed liquor recycle (MLR) pumps. New dissolved oxygen (DO) control, air piping and piping and valves.

- Three new aeration blowers (2 duty and 1 standby) are installed in the membrane building blower room.
- Three new membrane tanks are constructed with the ancillaries, i.e. the new membrane feed pumps, chemical cleaning system and chemical storage & metering pumps. GE/Zenon's scope includes membrane cassettes, membrane blowers, permeate and backpulse pumps, headers and chemical feed system.
- The cost for retrofitting the existing primary clarifier to a new chlorine contact chamber is proposed and included in the cost estimate, but refinements of this alternative could modify this approach.
- As with all other alternatives, a 3,000-sqft new Administration/O&M building is constructed.
- As with all other alternatives, a new emergency generator is installed onsite. For MBR alternative, the generator capacity is 250 kw as opposed to 200 kw assumed for other three alternatives due to the higher power requirement of MBR system.
- As with all other alternatives, no odor control is included. This should be evaluated in detail as the project progresses. It may be warranted to have odor control on the new parcel for the headworks facility.

Figures 3 and 4 show the existing site plan and proposed process changes on the site plan. Figures 5 and 6 illustrate the process flow diagram during normal operation and peak flow.

FIGURE 3
Coos Bay WWTP No.2 Existing Site Plan




FIGURE 4

Coos Bay WWTP No.2 Site Plan with Proposed Modification, VA Alternative 1 - MBR




FIGURE 5

VA Alternative 1 – MBR Process Flow Diagram (Normal Operation, Non-peak Flow Condition)





FIGURE 6

VA Alternative 1 – MBR Process Flow Diagram (Blending, Peak Flow Condition)



Construction Approach. The constructability of a treatment alternative utilizing the existing WWTP site is a significant concern as the treatment facility must remain in operation. An alternative is to provide a level of temporary treatment through the use of a package system or similar, but this could prove costly. The concept for the proposed improvement to the existing site is to keep the existing system in operation without the use of temporary treatment. For VA Alternative 1, the constructability approach proposed is:

1. Construct the new influent pump station, headworks, and administration/O&M building on the new parcel – once this is complete and brought into service, the existing headworks and administration building could be demolished, providing space for future unit processes.
2. Construct the membrane tanks, RAS pumps, and membrane building (blowers, permeate pumps, chemical systems) – this is to be constructed in the existing location of the Control Building. The remaining unit processes will be in service, operating under typical conditions.
3. Aeration Basin Retrofit. In discussions with WWTP operations, it may be possible to remove one aeration basin from service from April through October. If this timeframe is available, it would be feasible to take one aeration basin offline and complete the required modifications (diffused aeration system, baffle walls, PE and ML piping re-configured). Once the retrofitted aeration basin is available for use, this could be brought back into service (and the other aeration basin taken offline for modifications). At this time the secondary clarifiers could be phased out of operation, while the membrane tanks are brought into service.
4. Secondary Clarifiers converted to Primary Clarifier 1 and 2. With the MBR in service, the existing secondary clarifiers could be converted to the primary clarifiers. Major yard piping improvements would be required at this time, with periodic unit process shutdowns and connections required.
5. Existing Primary Clarifier converted to a Chlorine Contact Chamber. To provide additional chlorine contact chamber volume, the existing primary clarifier volume could be utilized.


This approach for construction is a concept at this phase, but it does appear feasible to continue providing treatment at the existing site while improvements are completed.

Value Assessment Alternative 2 – IFAS

This VA alternative includes the conversion of the existing WWTP to the IFAS treatment process. IFAS processes, depicted in Figure 7, combine suspended growth and biofilm compartments in a single bioreactor. Most IFAS applications are for nitrogen removal where free-moving plastic biofilm carriers are added to one or two aerobic bioreactor cells to enhance system capacity for nitrification. In these systems nitrifiers grow selectively in the biofilm and oxidize ammonium (provided the operational condition results in nitrifiers washing out of the suspended growth compartment) while the suspended biomass largely removes soluble and particulate organic matter and facilitates denitrification in the anoxic zone(s). The short solids retention time (SRT) typical of IFAS processes (e.g., 3 to 5 days) can result in a significant increase in process capacity, while providing the nitrification required.

FIGURE 7

VA Alternative 1 – IFAS Process Flow Diagram (Blending, Peak Flow Condition)



The following assumptions are made regarding the major processes and equipment in this alternative:

- New influent pump station with four submersible pumps (3 duty and 1 standby) – located on parcel across the street
- New headworks/screening facility on parcel across the street (greenfield site). The facility consists of two mechanical bar screens (6-mm maximum screen opening) and one bypass channel with manual clean bar screen, one vortex grit removal system and all the ancillary equipment.
- The two aeration basins are converted to the IFAS system – including anoxic selectors, aerobic zone, and IFAS zone. The IFAS zone contains the free-moving plastic biofilm carriers, where preliminary sizing indicates a 44% fill (by IFAS Zone volume). Other features particular to the IFAS system include the plastic biofilm carrier retention screens and coarse-bubble aeration system. A coarse-bubble system is required to keep the buoyant biofilm carriers completely mixed within the IFAS zone. For this alternative it is assumed that the non-IFAS, aerobic zones will also include coarse-bubble diffusers.
- Two existing secondary clarifiers are converted to the primary clarifiers. This modification is similar to that proposed for VA Alternative 1, but the CEPT modifications are not required.
- Two new 60-foot diameter secondary clarifiers are to be constructed. During the peak wet weather events, a portion of the primary effluent would be routed around the IFAS zone within the bioreactor to a re-aeration reactor at the end of the aeration basin. This wet weather flow will blend with the mixed-liquor for treatment in the new secondary clarifiers. This approach allows for the aeration basins to be cost-effectively sized for the average day maximum month dry and wet weather conditions.
- New primary sludge pump station.
- Three new aeration blowers (2 duty and 1 standby) are installed in a new blower building.
- The cost for retrofitting the existing primary clarifier to a new chlorine contact chamber is proposed and included in the cost estimate, but refinements of this alternative could modify this approach.
- As with all other alternatives, a 3,000-sqft new Administration/O&M building is constructed on the new parcel.

- As with all other alternatives, a new emergency generator is installed onsite. For this IFAS alternative a 200 kw unit is assumed.
- As with all other alternatives, no odor control is included. This should be evaluated in detail as the project progresses. It may be warranted to have odor control on the new parcel for the headworks facility.

Construction Approach. As with VA Alternative 1, the constructability of a treatment alternative utilizing the existing WWTP site is a significant concern as the treatment facility must remain in operation. The concept for the proposed improvement to the existing site is to keep the existing system in operation without the use of temporary treatment. For VA Alternative 2, the constructability approach proposed is:

1. Construct the new influent pump station, headworks, and administration/O&M building on the new parcel – once this is complete and brought into service, the existing headworks and administration building could be demolished, providing space for future unit processes.
2. Construct the Blower Building. With the aeration blowers installed, the conversion of the aeration basins to the IFAS system could start.
3. Aeration Basin Retrofit. As noted above, it may be possible to remove one aeration basin from service from April through October. If this timeframe is available, it would be feasible to take one aeration basin offline and complete the required modifications (coarse-bubble aeration system, baffle walls, PE and ML piping re-configured, IFAS system). It is also proposed that the walls be raised, allowing an increase in the water surface. This, together with the new Secondary Clarifiers, will allow for the secondary pump station to be removed from service. Once the retrofitted aeration basin is available for use, this could be brought back into service (and the other aeration basin taken offline for modifications).
4. Construction of two, new secondary clarifiers – a new Return Activated Sludge (RAS) pump station would be included. The new secondary clarifiers would be installed at an elevation allowing for ML to flow by gravity from the retrofitted aeration basins. Major yard piping improvements would be required at this time, with periodic unit process shutdowns and connections required.
5. Secondary Clarifiers converted to Primary Clarifier 1 and 2. Major yard piping improvements would be required for this phase as well, with periodic unit process shutdowns and connections required.
6. Existing Primary Clarifier converted to a Chlorine Contact Chamber. To provide additional chlorine contact chamber volume, the existing primary clarifier volume could be utilized.

This approach for construction is a concept at this phase, but similar to the previous VA alternative it does appear feasible to continue providing treatment at the existing site while improvements are completed.

The proposed site layout for VA Alternative 2 is presented in Figure 8. As noted, the new influent pump station, headworks facility, and administration/O&M building would be constructed on the new site. Figure 9 presents a process flow diagram for this alternative.

FIGURE 8

Coos Bay WWTP No.2 Site Plan with Proposed Modification, VA Alternative 2 - IFAS





FIGURE 9
VA Alternative 2 – IFAS Process Flow Diagram




Cost Estimate and Summary

The objective of the life-cycle cost evaluation is to provide a comparison between the alternatives. Given the conceptual level of the alternative evaluation, the cost opinion includes contingencies and markups for each alternative. During future design phases contingencies and allowances to capture additional project costs are refined and reduced as design details become available, allowing for a more detailed cost estimate. These estimates are intended to be used only for comparing initial conceptual alternatives for the purpose of screening them to a reasonable few for further evaluation.

This estimating effort adopts the classification of estimates as defined by the Association for the Advancement of Cost Engineering (AACE). The industry classification system is Recommended Practice-17R-97: "Cost Estimate Classification System" and 18R-97: "Cost Estimating Classification System as Applied in Engineering, Procurement, and Construction for the Process Industries."

Figure 10 shows the relationship of level of detail to the expected accuracy of the estimate.

FIGURE 10
Construction Cost Estimate Accuracy Ranges



The capital costs within this project definition report are defined as order-of-magnitude-level (Class 4) estimate as defined in the AACE International Recommended Practice No. 18R-97, *Cost Estimate Classification System As Applied in Engineering, Procurement, and Construction for the Process Industries*. An estimate of this type is normally expected to be within +50 percent or –30 percent of the actual construction cost. The final cost of the projects will depend on actual labor and materials costs, actual site conditions, productivity, competitive market conditions, bid dates, seasonal fluctuations, final project scope, final project schedule, and other variables. As a result, the final project costs will vary from the estimates presented in this report.

Capital and operation and maintenance (O&M) cost opinions will be developed to allow comparison of alternatives for a 20-year planning period.

The costs included in this evaluation are:

- **Capital Costs.** Capital costs are associated with building new facilities or expanding and renovating existing facilities. Capital costs shall include construction costs, non-construction costs, and land acquisition costs, and other factors identified as follows:

The facility construction cost includes the cost for building a new unit process or treatment facility in order to satisfy a specific treatment objective. In addition, other project elements are typically needed to integrate the new unit process or treatment facility into the WWTP. The additional project elements are calculated as a percentage of the facility construction cost. The additional project elements include demolition (2% for FPA alternatives and 5% for VA alternatives), overall site work (5%), plant computer system (5%), yard electrical (3%), and yard piping (5%). The sum of the facility construction cost and the additional project elements is a construction cost subtotal. Higher demolition percentage was used for VA alternatives than the FPA alternatives because VA alternatives require demolition and modification of the existing plant to a much larger extent.

Contractor markups shall be added to the construction cost subtotal. Contractor markups include overhead (10%); profit (5%); mobilization, bonds, and insurance (5%). Construction contingency (25%) is also added to the construction cost subtotal with markups.

In addition to construction costs, an allowance for non-construction costs shall be provided. The non-construction cost allowance is calculated as percentage of the construction cost subtotal with the contractor markups. For this evaluation an allowance for permitting/admin (5%); engineering (10%), services during construction (5%); commissioning and start-up (5%) are included as non-construction costs. (25% total)

Land Acquisition costs are assumed to be zero for the WWTP as the City owns all existing property required.

For this evaluation all capital costs are based on January 2012 dollars. An escalation factor to adjust the construction cost subtotal to the mid-point of construction in order to properly budget and account for inflation that may occur during planning, design, and construction of the project should be included once the project is better defined. Current economic conditions have resulted in a very competitive bid environment that has the effect of lowering contractor bid prices. CH2M HILL anticipates construction costs to be higher in Coos Bay, Oregon, but expects the current competitive bid environment to offset the higher costs. Therefore, there is no net effect on the overall construction cost estimates presented.

- Operation and Maintenance Costs.** O&M costs are associated with the daily requirements for maintaining and operating the wastewater treatment facilities. O&M costs include labor, power, chemicals, equipment maintenance, and equipment replacement. An additional increment of O&M costs are estimated for each alternative and presented in 2012 dollars for the first year and then escalated based on the inflation rate for 20 years. A 20-percent contingency is added to obtain the total estimated incremental O&M costs. The incremental O&M costs are increased each year by 3 percent. For this evaluation the O&M costs are based on the following factors:
 - Labor: no additional labor is planned for the four alternatives evaluated
 - Power: \$0.082/kilowatt-hour (includes usage, demand, and transmission charges)
 - Ferric chloride used in CEPT is approximately 40 mg/L for four month per year in winter. Ferric Chloride (40 percent solution): \$372/dry ton
 - Equipment Maintenance Materials: Figured as a percentage of the initial capital cost (2% finishes, 1% equipment, 0.1% mechanical, and 1% electrical)
- Life-cycle Cost.** The life-cycle cost analysis converts all expenditures that occur during the project into a single equivalent present value sum at the time of the analysis. Thus, the streams of expenditures associated with each alternative can be compared on the same basis.

It is assumed that the construction can be financed at an annual discount rate of 5 percent per year, and inflation is about 3 percent per year. The real value of money is the discount rate less the inflation rate, or about 2 percent per year.

The life-cycle cost is defined as the following, where P_w is the present worth: Life Cycle Cost = P_w (Construction Cost) + P_w (Operation and Maintenance Cost).

Table 3 lists the capital costs of all four alternatives in 2012 dollars.

TABLE 3
Capital Costs of All Alternatives for Coos Bay WWTP No.2

	FPA Alternative 1 SBR	FPA Alternative 2 MLE	VA Alternative 1 MBR	VA Alternative 2 IFAS
Project Cost (exclude contractor markups)	\$11,517,000	\$15,299,000	\$14,428,000	\$11,599,000
Construction Cost (include contractor markups)	\$17,774,000 ¹	\$23,506,000 ¹	\$21,874,000	\$17,584,000
Capital Cost (include contractor markups and	\$22,219,000	\$29,385,000	\$27,344,000	\$21,983,000

TABLE 3

Capital Costs of All Alternatives for Coos Bay WWTP No.2

	FPA Alternative 1	FPA Alternative 2	VA Alternative 1	VA Alternative 2
	SBR	MLE	MBR	IFAS
non-construction cost)				

Note 1: The construction cost for the Facility Plan Alternatives includes the allowance provided in the report for gravity system upgrades and estuary outfall piping and connection.

Table 4 below summarizes the O&M and life cycle cost of all four alternatives for Coos Bay WWTP No.2

TABLE 4

O&M and Life Cycle Costs of All Alternatives for Coos Bay WWTP No.2

	FPA Alternative 1	FPA Alternative 2	VA Alternative 1	VA Alternative 2
	SBR	MLE	MBR	IFAS
O&M Cost	\$584,000	\$623,000	\$838,000	\$569,000
Life Cycle Cost	\$24,701,000	\$30,888,000	\$32,232,000	\$24,571,000

From this evaluation, it appears that the Facility Plan Alternative 1 – SBR (ICEAS) and VA Alternative 2 – IFAS result in equivalent capital and life-cycle costs. At this level of detail, the difference in cost is well within the accuracy of the estimate to be considered equal. The other two options result in higher capital and life-cycle costs. Note, however, that VA Alternative 1 – MBR does provide a significantly higher water quality standard than the other alternatives. These alternatives have not been incorporated into a cost-benefit analysis, where non-monetary criteria (similar to those developed during the VA study) could impact any project selection.

It is noted previously that these estimates are not recommended for financial planning or rate impact analysis due to the conceptual nature of the estimate and associated level of accuracy. However, the use of CPES has been successful in providing cost estimates for facility plan efforts. From this evaluation it does appear that a project to upgrade or replace WWTP No.2 would have a capital cost of approximately \$22,000,000.

Cost Considerations

This section presents a number of items that may impact the overall capital cost for the respective alternatives. In general, these are listed as possible approaches to help reduce the overall cost of the project. These are presented for each alternative:

Facility Plan Amendment – Alternative 1 and 2

The cost consideration items are similar for both the SBR and Extended Aeration alternatives. Following are a list of considerations:

- Utilize existing digesters on the WWTP No.2 site for WAS storage. This results in additional WAS piping, but this could be constructed along with the plant effluent piping to help minimize the costs.
- Use chlorine disinfection instead of UV. The peak wet weather flow significantly impacts the costs of the UV system, and it appears significant savings are available with the use of a chlorine-based system. To handle flows with a big peaking factor, even for a short period of time, the UV system needs to be oversized with sufficient lamps to provide required UV dose at the peak flows; while the chlorine-based system just needs to provide higher chlorine dose at the peak flow to ensure the required CT (concentration x contact time). Based on the cost estimate performed using CPESTM, assuming the existing chlorinators could be reused, the construction cost of the new chlorine contact basins to handle 8.1 mgd flow is only 25 percent of the cost of the new UV facility with the same capacity.
- Demolish and/or rehabilitation of existing site. A cost consideration for the demolition or rehabilitation of the existing WWTP No.2 site was not included in this evaluation.

- Odor control should be considered for the headworks facility at the new parcel.

Value Assessment – Alternative 1 and 2

- Rebuild existing clarifier mechanisms instead of complete replacement. For this evaluation, the complete replacement of the clarifier mechanisms is assumed but possible savings may be available through the refurbishment of the systems.
- Construction Phasing Opportunities. With the continued use of the existing site, there appears to be opportunities to phase the construction over time if warranted. As an example, a new Headworks Facility could be constructed on the new parcel in the initial phase – with continued use of the existing WWTP No.2. Improvements to existing WWTP No.2 (or additional construction on the new parcel) could follow.
- For Alternative 2 there may be an opportunity to complete the work on new parcel as noted, followed by the conversion to the IFAS system. However, the continued use of the existing primary clarifier and secondary clarifiers may be a possibility. Allowances for addressing the periodic peak wet weather conditions would be required, but there may be an opportunity to reduce the overall project cost.
- Odor control should be considered for the headworks facility at the new parcel.

Attachment

CPESTM Cost Estimate Summary

FPA Alternative 1 - SBR

	A	B	C	D	E
1	<u>C</u> H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)				
2					
3	FACILITIES DESIGN & CONSTRUCTION COST MODULE				
4					
5	<u>File Version:</u> 1/25/2012	Click for CPES QA/QC	To Concrete Wall Thickness Help	To Cost Summary Matrix	To Unit Cost Database
6					
7					
8	Project Name:	<u>Coos Bay VA Cost Estimate</u>			
9	Project Number:				
10	Project Manager:	<u>Alan Chang</u>			
11	Estimator:	<u>Miaomiao Zhang</u>			
12	Project Description:	<u>FPA Alternative 1 - SBR with ICEAS</u>			
13	Project Location (City):	<u>Default</u>	Roundup to the nearest:		
14	Project Location (State):	<u>N/A</u>	\$1,000		
15	Project Location (Country):				
16	Construction Start (Month):	<u>Jan</u>	☐ This Report is for INTERNAL Distribution		
17	Construction Start (Year):	<u>2012</u>			
18	Construction Duration (months):	<u>1</u>	☐ This Report is for EXTERNAL Distribution		
19	Mid-Point of Construction:	<u>Feb /2012</u>			
20					
21	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT		Cost
22		Yes	<u>Submersible IPS: New</u>		\$1,228,000
23		Yes	<u>Screening and Grit: New</u>		\$1,883,000
24		Yes	<u>Aeration Basin: SBR</u>		\$2,990,000
25		Yes	<u>Blowers: BldgOnly</u>		\$514,000
26		Yes	<u>LPHO UV: New</u>		\$1,189,000
27		Yes	<u>WAS Storage: New</u>		\$827,000
28		No	<u>GBT: New</u>		\$0
29		No	<u>RAS WAS PS: WASPump</u>		\$0
30		Yes	<u>O&M Building: New</u>		\$755,000
31		No	<u>Demolition: New</u>		\$0
32		No	<u>Gravity Pipe: New</u>		\$0
33		Yes	<u>Emergency Generator: New</u>		\$211,000
34		No	<u>U.D. Facility: New</u>		\$0
35					
36	SUBTOTAL - PROJECT COST				\$9,597,000
37					
38	ADDITIONAL PROJECT COSTS:				
39	Demolition		2%		\$192,000
40	Overall Sitework		5%		\$480,000
41	Plant Computer System		5%		\$480,000
42	Yard Electrical		3%		\$288,000
43	Yard Piping		5%		\$480,000
44	UD #1 Default Description		0%		\$0
45	UD #2 Default Description		0%		\$0
46	UD #3 Default Description		0%		\$0
47	SUBTOTAL with Additional Project Costs				\$11,517,000
48					
49	TAX:		0.00%	\$11,517,000	\$0
50	SUBTOTAL with Tax				\$11,517,000
51					
52	CONTRACTOR MARKUPS:				
53	Overhead		10%	\$11,517,000	\$1,152,000

	A	B	C	D	E
54	Subtotal				\$12,669,000
55	Profit		5%	\$12,669,000	\$634,000
56	Subtotal				\$13,303,000
57	Mob/Bonds/Insurance		5%	\$13,303,000	\$666,000
58	Subtotal				\$13,969,000
59	Contingency		25%	\$13,969,000	\$3,493,000
60	SUBTOTAL with Markups				\$17,462,000
61					
62	ESCALATION (to Mid-Point of Construction)		0.0%	\$17,462,000	\$0
63	SUBTOTAL with Escalation				\$17,462,000
64					
65	LOCATION ADJUSTMENT FACTOR		100	\$17,462,000	\$17,462,000
66	SUBTOTAL - with Local Adjustment Factor				\$17,462,000
67					
68	RED FLAGS:				
69	1	Rock Excavation			
70	2	Pile Foundations			
71	3	Seismic Foundations			
72	4	Dewatering Conditions			
73	5	Wetlands Mitigation			
74	6	Weather Impacts			
75	7	Depth of Structures			
76	8	Local Building Code Restrictions			
77	9	Coatings or Finishes			
78	10	Building or Architectural Considerations			
79	11	Client Material Preferences			
80	12	Client Equipment Preferences			
81	13	Piping Galleries, Piping Trenches, Piping Racks			
82	14	Yard Piping Complexity			
83	15	Existing Site Utilities (New, Retrofit, and Complexity)			
84	16	I & C Automation (New or Retrofit)			
85	17	Electrical Feed (New or Retrofit)			
86	18	Electrical Distribution			
87	19	Shoring			
88	20	Contamination			
89	21	Gravity System Upgrades			\$117,000
90	22	Estuary Outfall Piping and Connection			\$195,000
91	23	User Defined Red Flag 3			
92	24	User Defined Red Flag 4			
93	25	User Defined Red Flag 5			
94	26	User Defined Red Flag 6			
95	27	User Defined Red Flag 7			
96	TOTAL - RED FLAGS				\$312,000
97					
98	SUBTOTAL - CONSTRUCTION COST with Red Flags				\$17,774,000
99					
100	MARKET ADJUSTMENT FACTOR		0%	\$17,774,000	\$0
101	SUBTOTAL - CONSTRUCTION COST with Market Adjustment Factor				\$17,774,000
102	Your CPES Estimate MUST be reviewed by a Process person AND an Estimator:				
103	Name of Process Reviewer			Leaf	Click for Review
104	Name of Estimator Reviewer			Lawson	
	MAXIMUM CONSTRUCTION COST				\$17,774,000
105					
106					
107	NON-CONSTRUCTION COSTS:				
108	Permitting		5%	\$17,774,000	\$889,000
109	Engineering		10%	\$17,774,000	\$1,778,000
110	Services During Construction		5%	\$17,774,000	\$889,000

	A	B	C	D	E
111	Commissioning & Startup		5%	\$17,774,000	\$889,000
112	Land / ROW		0%	\$17,774,000	\$0
113	Legal / Admin		0%	\$17,774,000	\$0
114	Other Default Description		0%	\$17,774,000	\$0
115	SUBTOTAL - Non-Construction Costs				\$4,445,000
116					
117	TOTAL - CAPITAL COST				\$22,219,000
118					
119	Currency Conversion of TOTAL CAPITAL COST:				
120		Currency	Unit of Measure	Conversion Rate	Converted Amount
121		None	U.S.Dollar	1	22,219,000

	A	B	C	D	E	F
1	<u>C</u>H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)					
2	FACILITIES LIFE CYCLE COST ANALYSIS					
3						
4	File <u>1/23/2012</u>					
5	Version:		Import File: C:\Users\mzhang\Documents\Project\CoosBay\CEPS\CPES Facilities Public_CoosBay_SBR_v2.xlsm			Brows
6	Click for CPES QA/QC					
7	Project Name: Coos Bay VA Cost Estimate					
8	Project Number:					
9	Project Manager: Alan Chang					
10	Estimator: Miaomiao Zhang					
11	Project Description: FPA Alternative 1 - SBR with ICEAS					
12	Project Location (City): Default					
13	Project Location (State): N/A					
14	Project Location (Country):					
15	Construction Start (Month): Jan					
16	Construction Start (Year): 2012					
17	Construction Duration (months) 1					
18	Mid-Point of Construction: Feb /2012					
19						
20	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT	Construction Cost	Annual O&M Cost (Escalated)	Life Cycle Cost (NPV)
21		Yes	Submersible IPS: New	\$1,862,000	\$35,000	\$2,297,000
22		Yes	Screening and Grit: New	\$2,855,000	\$131,000	\$4,484,000
23		Yes	Aeration Basin: SBR	\$4,534,000	\$84,000	\$5,575,000
24		Yes	Blowers: BldgOnly	\$779,000	\$30,000	\$1,147,000
25		Yes	LPHO UV: New	\$1,803,000	\$148,000	\$3,647,000
26		Yes	WAS Storage: New	\$1,254,000	\$31,000	\$1,633,000
27		No	GBT: New	\$0	\$0	\$0
28		No	RAS WAS PS: WASPump	\$0	\$0	\$0
29		Yes	O&M Building: New	\$1,144,000	\$9,000	\$1,246,000
30		No	Demolition: New	\$0	\$0	\$0
31		No	Gravity Pipe: New	\$0	\$0	\$0
32		Yes	Emergency Generator: New	\$320,000	\$8,000	\$416,000
33		No	U.D. Facility: New	\$0	\$0	\$0
34						
35	Additional Project Costs:					
36	Biosolids Disposal			\$0	\$0	\$0
37	Standard Items			\$2,912,000	\$108,000	\$4,256,000
38	User Defined Items			\$0	\$0	\$0
39						
40	Plant O & M Labor				\$0	\$0
41						
42	TOTAL - Life Cycle Analysis			\$17,463,000	\$584,000	\$24,701,000
43	Construction Cost per GPD (based on Maximum Daily Flow Rate)			\$2.80 / GPD		
44						
45						
46	Annual O & M Cost per 1,000 Gallons (based on Average Annual Daily Flow Rate)				\$ 1.081 / Thousand Gallons	

FPA Alternative 2 - MLE

	A	B	C	D	E
1	<u>C</u> H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)				
2	FACILITIES DESIGN & CONSTRUCTION COST MODULE				
3					
4					
5	File Version: 1/25/2012	Click for CPES QA/QC	To Concrete Wall Thickness Help	To Cost Summary Matrix	To Unit Cost Database
6					
7					
8	Project Name:	<u>Coos Bay VA Cost Estimate</u>			
9	Project Number:				
10	Project Manager:	<u>Alan Chang</u>			
11	Estimator:	<u>Miaomiao Zhang</u>			
12	Project Description:	<u>FPA Alternative 2 - Extended Aeration MLE</u>			
13	Project Location (City):	<u>Default</u>	Roundup to the nearest:		
14	Project Location (State):	<u>N/A</u>	\$1,000		
15	Project Location (Country):				
16	Construction Start (Month):	<u>Jan</u>	☐ This Report is for INTERNAL Distribution		
17	Construction Start (Year):	<u>2012</u>			
18	Construction Duration (months):	<u>1</u>	☐ This Report is for EXTERNAL Distribution		
19	Mid-Point of Construction:	<u>Feb /2012</u>			
20					
21	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT		Cost
22		Yes	<u>Submersible IPS: New</u>		\$1,228,000
23		Yes	<u>Screening and Grit: New</u>		\$1,883,000
24		Yes	<u>Aeration Basin: Main</u>		\$3,161,000
25		Yes	<u>Blowers: Main</u>		\$1,291,000
26		Yes	<u>Round SC: Main</u>		\$1,402,000
27		Yes	<u>RAS WAS PS: Main</u>		\$907,000
28		Yes	<u>LPHO UV: New</u>		\$1,189,000
29		Yes	<u>WAS Storage: New</u>		\$827,000
30		Yes	<u>O&M Building: New</u>		\$755,000
31		Yes	<u>Demolition: New</u>		\$0
32		Yes	<u>Emergency Generator: New</u>		\$211,000
33					
34	SUBTOTAL - PROJECT COST				\$12,854,000
35					
36	ADDITIONAL PROJECT COSTS:				
37	Demolition		2%		\$258,000
38	Overall Sitework		5%		\$643,000
39	Plant Computer System		2%		\$258,000
40	Yard Electrical		5%		\$643,000
41	Yard Piping		5%		\$643,000
42	UD #1 Default Description		0%		\$0
43	UD #2 Default Description		0%		\$0
44	UD #3 Default Description		0%		\$0
45	SUBTOTAL with Additional Project Costs				\$15,299,000
46					
47	TAX:		0.00%	\$15,299,000	\$0
48	SUBTOTAL with Tax				\$15,299,000
49					
50	CONTRACTOR MARKUPS:				
51	Overhead		10%	\$15,299,000	\$1,530,000
52	Subtotal				\$16,829,000
53	Profit		5%	\$16,829,000	\$842,000

	A	B	C	D	E
54		Subtotal			\$17,671,000
55		Mob/Bonds/Insurance	5%	\$17,671,000	\$884,000
56		Subtotal			\$18,555,000
57		Contingency	25%	\$18,555,000	\$4,639,000
58		SUBTOTAL with Markups			\$23,194,000
59					
60		ESCALATION (to Mid-Point of Construction)	0.0%	\$23,194,000	\$0
61		SUBTOTAL with Escalation			\$23,194,000
62					
63		LOCATION ADJUSTMENT FACTOR	100	\$23,194,000	\$23,194,000
64		SUBTOTAL - with Local Adjustment Factor			\$23,194,000
65					
66		RED FLAGS:			
67	1	Rock Excavation			
68	2	Pile Foundations			
69	3	Seismic Foundations			
70	4	Dewatering Conditions			
71	5	Wetlands Mitigation			
72	6	Weather Impacts			
73	7	Depth of Structures			
74	8	Local Building Code Restrictions			
75	9	Coatings or Finishes			
76	10	Building or Architectural Considerations			
77	11	Client Material Preferences			
78	12	Client Equipment Preferences			
79	13	Piping Galleries, Piping Trenches, Piping Racks			
80	14	Yard Piping Complexity			
81	15	Existing Site Utilities (New, Retrofit, and Complexity)			
82	16	I & C Automation (New or Retrofit)			
83	17	Electrical Feed (New or Retrofit)			
84	18	Electrical Distribution			
85	19	Shoring			
86	20	Contamination			
87	21	Gravity System Upgrades			\$117,000
88	22	Estuary Outfall Piping and Connection			\$195,000
89	23	User Defined Red Flag 3			
90	24	User Defined Red Flag 4			
91	25	User Defined Red Flag 5			
92	26	User Defined Red Flag 6			
93	27	User Defined Red Flag 7			
94		TOTAL - RED FLAGS			\$312,000
95					
96		SUBTOTAL - CONSTRUCTION COST with Red Flags			\$23,506,000
97					
98		MARKET ADJUSTMENT FACTOR	0%	\$23,506,000	\$0
99		SUBTOTAL - CONSTRUCTION COST with Market Adjustment Factor			\$23,506,000
100	Your CPES Estimate MUST be reviewed by a Process person AND an Estimator:				
101	Name of Process Reviewer			Leaf	Click for Review
102	Name of Estimator Reviewer			Lawson	
	MAXIMUM CONSTRUCTION COST				\$23,506,000
103					
104					
105	NON-CONSTRUCTION COSTS:				
106	Permitting		5%	\$23,506,000	\$1,176,000
107	Engineering		10%	\$23,506,000	\$2,351,000
108	Services During Construction		5%	\$23,506,000	\$1,176,000
109	Commissioning & Startup		5%	\$23,506,000	\$1,176,000
110	Land / ROW		0%	\$23,506,000	\$0

	A	B	C	D	E
111	Legal / Admin		0%	\$23,506,000	\$0
112	Other Default Description		0%	\$23,506,000	\$0
113	SUBTOTAL - Non-Construction Costs				\$5,879,000
114					
115	TOTAL - CAPITAL COST				\$29,385,000
116					
117	Currency Conversion of TOTAL CAPITAL COST:				
118		Currency	Unit of Measure	Conversion Rate	Converted Amount
119		None	U.S.Dollar	1	29,385,000

	A	B	C	D	E	F
1	<u>C</u>H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)					
2	FACILITIES LIFE CYCLE COST ANALYSIS					
3						
4	File <u>1/23/2012</u>					
5	Version:		Import File: C:\Users\mzhang\Documents\Project\CoosBay\CEPS\CPES Facilities Public_CoosBay_MLE_v2.xlsm			Brows
6	Click for CPES QA/QC					
7	Project Name: Coos Bay VA Cost Estimate					
8	Project Number:					
9	Project Manager: Alan Chang					
10	Estimator: Miaomiao Zhang					
11	Project Description: FPA Alternative 2 - Extended Aeration MLE					
12	Project Location (City): Default					
13	Project Location (State): N/A					
14	Project Location (Country):					
15	Construction Start (Month): Jan					
16	Construction Start (Year): 2012					
17	Construction Duration (months) 1					
18	Mid-Point of Construction: Feb /2012					
19						
20	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT	Construction Cost	Annual O&M Cost (Escalated)	Life Cycle Cost (NPV)
21		Yes	Submersible IPS: New	\$1,862,000	\$35,000	\$2,297,000
22		Yes	Screening and Grit: New	\$2,854,000	\$131,000	\$4,483,000
23		Yes	Aeration Basin: Main	\$4,793,000	\$30,000	\$5,160,000
24		Yes	Blowers: Main	\$1,957,000	\$46,000	\$2,520,000
25		Yes	Round SC: Main	\$2,125,000	\$31,000	\$2,505,000
26		Yes	RAS WAS PS: Main	\$1,375,000	\$19,000	\$1,603,000
27		Yes	LPHO UV: New	\$1,803,000	\$149,000	\$3,654,000
28		Yes	WAS Storage: New	\$1,254,000	\$31,000	\$1,634,000
29		Yes	O&M Building: New	\$1,144,000	\$9,000	\$1,246,000
30		Yes	Demolition: New	\$0	\$0	\$0
31		Yes	Emergency Generator: New	\$320,000	\$8,000	\$416,000
32						
33	Additional Project Costs:					
34	Biosolids Disposal			\$0	\$0	\$0
35	Standard Items			\$3,707,000	\$134,000	\$5,370,000
36	User Defined Items			\$0	\$0	\$0
37						
38	Plant O & M Labor				\$0	\$0
39						
40	TOTAL - Life Cycle Analysis			\$23,194,000	\$623,000	\$30,888,000
41	Construction Cost per GPD (based on Maximum Daily Flow Rate)			\$3.72 / GPD		
42						
43						
44	Annual O & M Cost per 1,000 Gallons (based on Average Annual Daily Flow Rate)			\$ 1.153 / Thousand Gallons		

VA Alternative 1 - MBR

	A	B	C	D	E
1	<u>C</u> H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)				
2					
3	FACILITIES DESIGN & CONSTRUCTION COST MODULE				
4					
5	<u>File Version: 1/25/2012</u>	Click for CPES QA/QC	To Concrete Wall Thickness Help	To Cost Summary Matrix	To Unit Cost Database
6					
7					
8	Project Name:	<u>Coos Bay VA Cost Estimate</u>			
9	Project Number:				
10	Project Manager:	<u>Alan Chang</u>			
11	Estimator:	<u>Miaomiao Zhang/Bill Leaf</u>			
12	Project Description:	<u>VA Alternative 1 - MBR with Existing Tanks</u>			
13	Project Location (City):	<u>Default</u>	Roundup to the nearest:		
14	Project Location (State):	<u>N/A</u>	\$1,000		
15	Project Location (Country):				
16	Construction Start (Month):	<u>Jan</u>	☐ This Report is for INTERNAL Distribution		
17	Construction Start (Year):	<u>2012</u>			
18	Construction Duration (months):	<u>1</u>	☐ This Report is for EXTERNAL Distribution		
19	Mid-Point of Construction:	<u>Feb /2012</u>			
20					
21	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT		Cost
22		Yes	<u>Submersible IPS: New</u>		\$1,238,000
23		Yes	<u>Screening and Grit: New</u>		\$3,272,000
24		Yes	<u>Primary Sludge PS: Main</u>		\$131,000
25		Yes	<u>Round PC: Main</u>		\$382,000
26		Yes	<u>Aeration Basin: Main</u>		\$667,000
27		Yes	<u>Blowers: Main</u>		\$821,000
28		Yes	<u>MBR: Main</u>		\$3,494,000
29		Yes	<u>Liquid Chemical: CEPTChem</u>		\$302,000
30		Yes	<u>Flow Splitting: CEPTBypass</u>		\$128,000
31		Yes	<u>O&M Building: New</u>		\$755,000
32		No	<u>Demolition: New</u>		\$0
33		Yes	<u>Emergency Generator: New</u>		\$237,000
34		Yes	<u>Oxidant Contactor: New</u>		\$301,000
35					
36	SUBTOTAL - PROJECT COST				\$11,728,000
37					
38	ADDITIONAL PROJECT COSTS:				
39	Demolition		5%		\$587,000
40	Overall Sitework		5%		\$587,000
41	Plant Computer System		5%		\$587,000
42	Yard Electrical		3%		\$352,000
43	Yard Piping		5%		\$587,000
44	UD #1 Default Description		0%		\$0
45	UD #2 Default Description		0%		\$0
46	UD #3 Default Description		0%		\$0
47	SUBTOTAL with Additional Project Costs				\$14,428,000
48					
49	TAX:		0.00%	\$14,428,000	\$0
50	SUBTOTAL with Tax				\$14,428,000
51					
52	CONTRACTOR MARKUPS:				
53	Overhead		10%	\$14,428,000	\$1,443,000

	A	B	C	D	E
54	Subtotal				\$15,871,000
55	Profit		5%	\$15,871,000	\$794,000
56	Subtotal				\$16,665,000
57	Mob/Bonds/Insurance		5%	\$16,665,000	\$834,000
58	Subtotal				\$17,499,000
59	Contingency		25%	\$17,499,000	\$4,375,000
60	SUBTOTAL with Markups				\$21,874,000
61					
62	ESCALATION (to Mid-Point of Construction)		0.0%	\$21,874,000	\$0
63	SUBTOTAL with Escalation				\$21,874,000
64					
65	LOCATION ADJUSTMENT FACTOR		100	\$21,874,000	\$21,874,000
66	SUBTOTAL - with Local Adjustment Factor				\$21,874,000
67					
68	RED FLAGS:				
69	1	Rock Excavation			
70	2	Pile Foundations			
71	3	Seismic Foundations			
72	4	Dewatering Conditions			
73	5	Wetlands Mitigation			
74	6	Weather Impacts			
75	7	Depth of Structures			
76	8	Local Building Code Restrictions			
77	9	Coatings or Finishes			
78	10	Building or Architectural Considerations			
79	11	Client Material Preferences			
80	12	Client Equipment Preferences			
81	13	Piping Galleries, Piping Trenches, Piping Racks			
82	14	Yard Piping Complexity			
83	15	Existing Site Utilities (New, Retrofit, and Complexity)			
84	16	I & C Automation (New or Retrofit)			
85	17	Electrical Feed (New or Retrofit)			
86	18	Electrical Distribution			
87	19	Shoring			
88	20	Contamination			
89	21	User Defined Red Flag 1			
90	22	User Defined Red Flag 2			
91	23	User Defined Red Flag 3			
92	24	User Defined Red Flag 4			
93	25	User Defined Red Flag 5			
94	26	User Defined Red Flag 6			
95	27	User Defined Red Flag 7			
96	TOTAL - RED FLAGS				\$0
97					
98	SUBTOTAL - CONSTRUCTION COST with Red Flags				\$21,874,000
99					
100	MARKET ADJUSTMENT FACTOR		0%	\$21,874,000	\$0
101	SUBTOTAL - CONSTRUCTION COST with Market Adjustment Factor				\$21,874,000
102	Your CPES Estimate MUST be reviewed by a Process person AND an Estimator:				
103	Name of Process Reviewer			Leaf	Click for Review
104	Name of Estimator Reviewer			Lawson	
	MAXIMUM CONSTRUCTION COST				\$21,874,000
105					
106					
107	NON-CONSTRUCTION COSTS:				
108	Permitting		5%	\$21,874,000	\$1,094,000
109	Engineering		10%	\$21,874,000	\$2,188,000
110	Services During Construction		5%	\$21,874,000	\$1,094,000

	A	B	C	D	E
111	Commissioning & Startup		5%	\$21,874,000	\$1,094,000
112	Land / ROW		0%	\$21,874,000	\$0
113	Legal / Admin		0%	\$21,874,000	\$0
114	Other Default Description		0%	\$21,874,000	\$0
115	SUBTOTAL - Non-Construction Costs				\$5,470,000
116					
117	TOTAL - CAPITAL COST				\$27,344,000
118					
119	Currency Conversion of TOTAL CAPITAL COST:				
120		Currency	Unit of Measure	Conversion Rate	Converted Amount
121		None	U.S.Dollar	1	27,344,000

	A	B	C	D	E	F
1	<u>C</u>H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)					
2	FACILITIES LIFE CYCLE COST ANALYSIS					
3						
4	File <u>1/23/2012</u>					
5	Version:		Import File: C:\Users\mzhang\Documents\Project\CoosBay\CEPS\CPES Facilities Public_CoosBay_MBR.xlsm			
6	Click for CPES QA/QC		Brows			
7	Project Name: Coos Bay VA Cost Estimate					
8	Project Number:					
9	Project Manager: Alan Chang					
10	Estimator: Miaomiao Zhang/Bill Leaf					
11	Project Description: VA Alternative 1 - MBR with Existing Tanks					
12	Project Location (City): Default					
13	Project Location (State): N/A					
14	Project Location (Country):					
15	Construction Start (Month): Jan					
16	Construction Start (Year): 2012					
17	Construction Duration (months) 1					
18	Mid-Point of Construction: Feb /2012					
19						
20	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT	Construction Cost	Annual O&M Cost (Escalated)	Life Cycle Cost (NPV)
21		Yes	Submersible IPS: New	\$1,876,000	\$35,000	\$2,311,000
22		Yes	Screening and Grit: New	\$4,961,000	\$221,000	\$7,711,000
23		Yes	Primary Sludge PS: Main	\$198,000	\$3,000	\$228,000
24		Yes	Round PC: Main	\$579,000	\$25,000	\$881,000
25		Yes	Aeration Basin: Main	\$1,011,000	\$21,000	\$1,261,000
26		Yes	Blowers: Main	\$1,244,000	\$28,000	\$1,587,000
27		Yes	MBR: Main	\$5,297,000	\$280,000	\$8,785,000
28		Yes	Liquid Chemical: CEPTChem	\$457,000	\$72,000	\$1,346,000
29		Yes	Flow Splitting: CEPTBypass	\$194,000	\$1,000	\$199,000
30		Yes	O&M Building: New	\$1,144,000	\$9,000	\$1,246,000
31		No	Demolition: New	\$0	\$0	\$0
32		Yes	Emergency Generator: New	\$359,000	\$10,000	\$474,000
33		Yes	Oxidant Contactor: New	\$456,000	\$1,000	\$466,000
34						
35	Additional Project Costs:					
36	Biosolids Disposal			\$0	\$0	\$0
37	Standard Items			\$4,094,000	\$132,000	\$5,737,000
38	User Defined Items			\$0	\$0	\$0
39						
40	Plant O & M Labor				\$0	\$0
41						
42	TOTAL - Life Cycle Analysis			\$21,870,000	\$838,000	\$32,232,000
43	Construction Cost per GPD (based on Maximum Daily Flow Rate)			\$3.50 / GPD		
44						
45						
46	Annual O & M Cost per 1,000 Gallons (based on Average Annual Daily Flow Rate)				\$ 1.551 / Thousand Gallons	

VA Alternative 2 - IFAS

	A	B	C	D	E
1	<u>C</u> H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)				
2	FACILITIES DESIGN & CONSTRUCTION COST MODULE				
3					
4					
5	<u>File Version: 1/25/2012</u>	Click for CPES QA/QC	To Concrete Wall Thickness Help	To Cost Summary Matrix	To Unit Cost Database
6					
7					
8	Project Name:	<u>Coos Bay VA Cost Estimate</u>			
9	Project Number:				
10	Project Manager:	<u>Alan Chang</u>			
11	Estimator:	<u>William Leaf/Miaomiao Zhang</u>			
12	Project Description:	<u>VA Alternative 2 - Integrated Fixed-film</u>			
13	Project Location (City):	<u>Activated Sludge</u>	Roundup to the nearest:		
14	Project Location (State):	<u>Default</u>	\$1,000		
15	Project Location (Country):	<u>N/A</u>			
16	Construction Start (Month):	<u>Jan</u>	☐ This Report is for INTERNAL Distribution		
17	Construction Start (Year):	<u>2012</u>			
18	Construction Duration (months):	<u>1</u>	☐ This Report is for EXTERNAL Distribution		
19	Mid-Point of Construction:	<u>Feb /2012</u>			
20					
21	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT		Cost
22		Yes	<u>Submersible IPS: New</u>		\$1,236,000
23		Yes	<u>Screening and Grit: New</u>		\$1,883,000
24		Yes	<u>Primary Sludge PS: Main</u>		\$131,000
25		Yes	<u>Round PC: Main</u>		\$360,000
26		Yes	<u>Aeration Basin: Main</u>		\$1,175,000
27		Yes	<u>Blowers: Main</u>		\$990,000
28		Yes	<u>Round SC: Main</u>		\$1,254,000
29		Yes	<u>RAS WAS PS: Main</u>		\$1,102,000
30		No	<u>Silo AnDiq: Meso</u>		\$0
31		Yes	<u>Oxidant Contactor: New</u>		\$301,000
32		Yes	<u>Liquid Chemical: New</u>		\$185,000
33		Yes	<u>O&M Building: New</u>		\$755,000
34		No	<u>Demolition: New</u>		\$0
35		Yes	<u>Emergency Generator: New</u>		\$211,000
36		No	<u>Yard Piping: New</u>		\$0
37		No	<u>U.D. Facility: New</u>		\$0
38					
39	SUBTOTAL - PROJECT COST				\$9,583,000
40					
41	ADDITIONAL PROJECT COSTS:				
42	Demolition	5%			\$480,000
43	Overall Sitework	5%			\$480,000
44	Plant Computer System	3%			\$288,000
45	Yard Electrical	3%			\$288,000
46	Yard Piping	5%			\$480,000
47	UD #1 Default Description	0%			\$0
48	UD #2 Default Description	0%			\$0
49	UD #3 Default Description	0%			\$0
50	SUBTOTAL with Additional Project Costs				\$11,599,000
51					
52	TAX:	0.00%	\$11,599,000		\$0

	A	B	C	D	E
53	SUBTOTAL with Tax				\$11,599,000
54					
55	CONTRACTOR MARKUPS:				
56	Overhead		10%	\$11,599,000	\$1,160,000
57	Subtotal				\$12,759,000
58	Profit		5%	\$12,759,000	\$638,000
59	Subtotal				\$13,397,000
60	Mob/Bonds/Insurance		5%	\$13,397,000	\$670,000
61	Subtotal				\$14,067,000
62	Contingency		25%	\$14,067,000	\$3,517,000
63	SUBTOTAL with Markups				\$17,584,000
64					
65	ESCALATION (to Mid-Point of Construction)		0.0%	\$17,584,000	\$0
66	SUBTOTAL with Escalation				\$17,584,000
67					
68	LOCATION ADJUSTMENT FACTOR		100	\$17,584,000	\$17,584,000
69	SUBTOTAL - with Local Adjustment Factor				\$17,584,000
70					
71	RED FLAGS:				
72	1	Rock Excavation			
73	2	Pile Foundations			
74	3	Seismic Foundations			
75	4	Dewatering Conditions			
76	5	Wetlands Mitigation			
77	6	Weather Impacts			
78	7	Depth of Structures			
79	8	Local Building Code Restrictions			
80	9	Coatings or Finishes			
81	10	Building or Architectural Considerations			
82	11	Client Material Preferences			
83	12	Client Equipment Preferences			
84	13	Piping Galleries, Piping Trenches, Piping Racks			
85	14	Yard Piping Complexity			
86	15	Existing Site Utilities (New, Retrofit, and Complexity)			
87	16	I & C Automation (New or Retrofit)			
88	17	Electrical Feed (New or Retrofit)			
89	18	Electrical Distribution			
90	19	Shoring			
91	20	Contamination			
92	21	User Defined Red Flag 1			
93	22	User Defined Red Flag 2			
94	23	User Defined Red Flag 3			
95	24	User Defined Red Flag 4			
96	25	User Defined Red Flag 5			
97	26	User Defined Red Flag 6			
98	27	User Defined Red Flag 7			
99	TOTAL - RED FLAGS				\$0
100					
101	SUBTOTAL - CONSTRUCTION COST with Red Flags				\$17,584,000
102					
103	MARKET ADJUSTMENT FACTOR		0%	\$17,584,000	\$0
104	SUBTOTAL - CONSTRUCTION COST with Market Adjustment Factor				\$17,584,000
105	Your CPES Estimate MUST be reviewed by a Process person AND an Estimator:				
106	Name of Process Reviewer			Leaf	Click for Review
107	Name of Estimator Reviewer			Lawson	
	MAXIMUM CONSTRUCTION COST				\$17,584,000
108					
109					

	A	B	C	D	E
110	NON-CONSTRUCTION COSTS:				
111	Permitting		5%	\$17,584,000	\$880,000
112	Engineering		10%	\$17,584,000	\$1,759,000
113	Services During Construction		5%	\$17,584,000	\$880,000
114	Commissioning & Startup		5%	\$17,584,000	\$880,000
115	Land / ROW		0%	\$17,584,000	\$0
116	Legal / Admin		0%	\$17,584,000	\$0
117	Other Default Description		0%	\$17,584,000	\$0
118	SUBTOTAL - Non-Construction Costs				\$4,399,000
119					
120	TOTAL - CAPITAL COST				\$21,983,000
121					
122	Currency Conversion of TOTAL CAPITAL COST:				
123		Currency	Unit of Measure	Conversion Rate	Converted Amount
124		None	U.S.Dollar	1	21,983,000

	A	B	C	D	E	F
1	<u>C</u>H2M HILL <u>P</u>arametric Cost <u>E</u>stimating <u>S</u>ystem (CPES)					
2	FACILITIES LIFE CYCLE COST ANALYSIS					
3						
4	File <u>1/23/2012</u>					
5	Version:		Import File: C:\Users\mzhang\Documents\Project\CoosBay\CEPS\CPES Facilities Public_CB_IFAS_v1.xlsm			Brows
6	Click for CPES QA/QC					
7	Project Name:		Coos Bay VA Cost Estimate			Life Cycle Analysis:
8	Project Number:					i = 5.00%
9	Project Manager:		Alan Chang			n = 20
10	Estimator:		William Leaf/Miaomiao Zhang			Annual 3.00%
11	Project Description:		VA Alternative 2 - Integrated Fixed-film Activated Sludge			Inflation %:
12	Project Location (City):		Default			To Global Life Cycle Data Sheet
13	Project Location (State):		N/A			To Annual O & M Cost Summary Sheet
14	Project Location (Country):					
15	Construction Start (Month):		Jan			☒ This Report is for INTERNAL Distribution
16	Construction Start (Year):		2012			☐ This Report is for EXTERNAL Distribution
17	Construction Duration (months):		1			
18	Mid-Point of Construction:		Feb /2012			
19						
20	Item	Is This Facility Included in Project? (Yes or No)	SCOPE OF PROJECT	Construction Cost	Annual O&M Cost (Escalated)	Life Cycle Cost (NPV)
21		Yes	Submersible IPS: New	\$1,862,000	\$35,000	\$2,297,000
22		Yes	Screening and Grit: New	\$2,855,000	\$131,000	\$4,487,000
23		Yes	Primary Sludge PS: Main	\$199,000	\$3,000	\$229,000
24		Yes	Round PC: Main	\$545,000	\$25,000	\$847,000
25		Yes	Aeration Basin: Main	\$1,781,000	\$56,000	\$2,467,000
26		Yes	Blowers: Main	\$1,501,000	\$36,000	\$1,938,000
27		Yes	Round SC: Main	\$1,902,000	\$44,000	\$2,447,000
28		Yes	RAS WAS PS: Main	\$1,671,000	\$24,000	\$1,962,000
29		No	Silo AnDig: Meso	\$0	\$0	\$0
30		Yes	Oxidant Contactor: New	\$456,000	\$1,000	\$466,000
31		Yes	Liquid Chemical: New	\$280,000	\$105,000	\$1,580,000
32		Yes	O&M Building: New	\$1,144,000	\$9,000	\$1,246,000
33		No	Demolition: New	\$0	\$0	\$0
34		Yes	Emergency Generator: New	\$320,000	\$8,000	\$416,000
35		No	Yard Piping: New	\$0	\$0	\$0
36		No	U.D. Facility: New	\$0	\$0	\$0
37						
38	Additional Project Costs:					
39	Biosolids Disposal			\$0	\$0	\$0
40	Standard Items			\$3,052,000	\$92,000	\$4,189,000
41	User Defined Items			\$0	\$0	\$0
42						
43	Plant O & M Labor				\$0	\$0
44						
45	TOTAL - Life Cycle Analysis			\$17,568,000	\$569,000	\$24,571,000
46	Construction Cost per GPD (based on Maximum Daily Flow Rate)			\$2.82 / GPD		
47						
48						
49	Annual O & M Cost per 1,000 Gallons (based on Average Annual Daily Flow Rate)				\$ 1.053 / Thousand Gallons	